



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

September 6, 2012

DEPT. OF SAFETY AND PROFESSIONAL SERV.
JERRY THOMPSON
201 W WASHINGTON AVE
MADISON WI 53701

Re: Description: ALTERNATE STANDARD
Manufacturer: DEPT. OF SAFETY AND PROFESSIONAL SERV.
Product Name: ASME A112.18.3-2002
Model Number(s): PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND
SYSTEMS IN PLUMBING FIXTURE FITTINGS
Product File No: 20120315

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.41 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This standard may only be used within a plumbing system for:

Cross connection protection for faucets with pull out hose-connected outlet.

For cross connection protection for a plumbing appliance connected to a highpurity water source (i.e. reverse osmosis (R.O.), deionized (DI) having a maximum flow rate of 2gpm and no more than 3/8" nominal pipe size supply.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov